

PROJECT MANUAL

**SHAW AIR FORCE BASE
AFTERBURNER GRILL, FLIGHT KITCHEN
BUILDING 1518.**

PREPARED FOR:

**UNITED STATES AIR FORCE
HQ AIR FORCE SERVICES CENTER**

Issue For 100% Ready To Advertise Submittal

08 18.25 RFI Response

TABLE OF CONTENTS Flight Kitchen

GENERAL

Cover Page
Table of Contents

GENERAL CONDITIONS

00 01 15	List of Drawings
00 22 13	Supplementary Instruction to Offerors
01 11 00	Summary of Work
01 14 00	Work Restrictions
01 20 00	Price and Payment Procedures
01 30 00	Administrative Requirements
01 31 23.13	20 Electronic Construction and Facility Support Contract Management System
01 32 01	Project Schedule
01 33 00	Submittal Procedures
01 35 26	Governmental Safety Requirements
01 42 00	Sources for Reference Publications
01 74 19	Construction Waste Management and Disposal
01 78 00	Closeout Submittals

TECHNICAL SPECS

02 41 00	Demolition and Deconstruction
02 84 16	Handling of Lighting Ballasts and Lamps Containing PCBs and Mercury
05 40 00	Cold Formed Metal Framing
06 20 00	Finish Carpentry
08 11 13	Steel Doors and Frames
08 71 00	Door Hardware
09 06 00	Schedules for Finishes
09 29 00	Gypsum Board
09 30 10	Ceramic, Quarry and Glass Tiling
09 51 00	Acoustic Ceilings
09 65 00	Resilient Flooring
09 68 00	Carpeting
09 90 00	Paints and Coatings
10 28 13	Toilet Accessories

FIRE PROTECTION

21 13 13	Wet Pipe Sprinkler System
----------	---------------------------

PLUMBING

22 00 00	Plumbing General Purpose
----------	--------------------------

MECHANICAL

23 00 00	Air Supply, Distribution, Ventilation and Exhaust Systems
----------	---

ELECTRICAL

26 20 00 Interior Distribution System

TECHNOLOGY

27 10 00 Building Telecommunications

FIRE ALARM

28 31 76 Interior Fire Alarm and Mass Notification System, Addressable.

100% RTA - FK RFI Response 08.18.25

SECTION 08 11 13

STEEL DOORS AND FRAMES

08/20

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN WELDING SOCIETY (AWS)

AWS D1.1/D1.1M (2020; Errata 1 2021) Structural Welding Code
- Steel

ASTM INTERNATIONAL (ASTM)

ASTM C578 (2022) Standard Specification for Rigid,
Cellular Polystyrene Thermal Insulation

ASTM C591 (2021) Standard Specification for Unfaced
Preformed Rigid Cellular Polyisocyanurate
Thermal Insulation

ASTM D2863 (2019) Standard Test Method for Measuring the
Minimum Oxygen Concentration to Support
Candle-Like Combustion of Plastics (Oxygen
Index)

BUILDERS HARDWARE MANUFACTURERS ASSOCIATION (BHMA)

ANSI/BHMA A156.115 (2016) Hardware Preparation in Steel Doors
and Steel Frames

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 80 (2022) Standard for Fire Doors and Other
Opening Protectives

NFPA 252 (2022) Standard Methods of Fire Tests of Door
Assemblies

STEEL DOOR INSTITUTE (SDI/DOOR)

SDI/DOOR 111 (2009) Recommended Details for Standard Steel
Doors, Frames, and Accessories and Related
Components

SDI/DOOR 113 (2013; R2018) Standard Practice for
Determining the Steady-State Thermal
Transmittance of Steel Door and Frame
Assemblies

SDI/DOOR A250.4	(2018) Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors
SDI/DOOR A250.6	(2015) Recommended Practice for Hardware Reinforcing on Standard Steel Doors and Frames
SDI/DOOR A250.8	(2017) Specifications for Standard Steel Doors and Frames
SDI/DOOR A250.11	(2012) Recommended Erection Instructions for Steel Frames

UNDERWRITERS LABORATORIES (UL)

UL 10C	(2016; Reprint May 2021) UL Standard for Safety Positive Pressure Fire Tests of Door Assemblies
--------	---

1.2 SUBMITTALS

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Doors; G
Frames; G
Accessories
Schedule of Doors; G
Schedule of Frames; G

SD-03 Product Data

Doors; G
Recycled Content for Steel Door Product; S
Frames; G
Recycled Content for Steel Frame Product; S
Accessories

SD-04 Samples

Factory-applied Enamel Finish; G

1.3 DELIVERY, STORAGE, AND HANDLING

Deliver doors, frames, and accessories undamaged and with protective wrappings or packaging. Strap knock-down frames in bundles. Provide temporary steel spreaders securely fastened to the bottom of each welded frame. Store doors and frames on platforms under cover in clean, dry, ventilated, and accessible locations, with 1/4 inch airspace between doors. Remove damp or wet packaging immediately and wipe affected surfaces dry. Replace damaged materials with new.

PART 2 PRODUCTS

2.1 STANDARD STEEL DOORS

SDI/DOOR A250.8, except as specified otherwise. Prepare doors to receive door hardware as specified in Section 08 71 00 DOOR HARDWARE. Undercut where indicated. Provide exterior doors with top edge closed flush and sealed to prevent water intrusion. Provide doors at 1-3/4 inch thick, unless otherwise indicated. Provide door material that uses a minimum of 25 percent recycled content. Provide data indicating percentage of recycled content for steel door product.

2.1.1 Classification - Level, Performance, Model

2.1.1.1 Extra Heavy Duty Doors

SDI/DOOR A250.8, Level 3, physical performance Level A, Model 1 with core construction as required by the manufacturer for interior insulated doors. Hinge pockets only prepped for one hand.

2.2 INSULATED STEEL DOOR SYSTEMS

all interior doors shall be insulated. Provide insulated steel doors with a core of polyurethane foam and an R factor of 10.0 or more based on a K value of 0.16, and construction of doors as specified herein; door seals as indicated. Provide to doors and frames a phosphate treatment, rust-inhibitive primer, and baked acrylic enamel finish. Test doors in accordance with SDI/DOOR A250.4 and meet the requirements for Level C. Prepare doors to receive specified hardware. Provide doors 1-3/4 inch thick.

]2.3 ACCESSORIES

2.3.1 Astragals

For pairs of exterior steel doors which will not have aluminum astragals or removable mullions, as specified in Section 08 71 00 DOOR HARDWARE provide overlapping steel astragals with the doors. For interior pairs of fire rated doors, provide stainless steel astragals complying with NFPA 80 for fire rated assemblies.

2.3.2 Moldings

Provide moldings around glass of interior and exterior doors and louvers of interior doors. Provide nonremovable moldings on outside of exterior doors and on corridor side of interior doors. Other moldings may be stationary or removable. Secure inside moldings to stationary moldings, or provide snap-on moldings.

2.4 INSULATION CORES

Provide insulating cores at all exterior doors and other specific doors noted in the door schedule], and provide an apparent U-factor of .48 in accordance with SDI/DOOR 113 and conforming to:

- a. Rigid Cellular Polyisocyanurate Foam: ASTM C591, Type I or II, foamed-in-place or in board form, with oxygen index of not less than 22 percent when tested in accordance with ASTM D2863; or
- b. Rigid Polystyrene Foam Board: ASTM C578, Type I or II

2.5 STANDARD STEEL FRAMES

SDI/DOOR A250.8, Level 3, at all interior frames. Form frames to sizes and shapes indicated, with welded corners. Provide steel frames for doors, transoms, sidelights, mullions, cased openings, and interior glazed panels, unless otherwise indicated. Provide frame product that uses a minimum of 25 percent recycled content. Provide data indicating percentage of recycled content for steel frame product.

2.5.1 Welded Frames

Continuously weld frame faces at corner joints. Mechanically interlock or continuously weld stops and rabbets. Grind welds smooth.

Weld frames in accordance with the recommended practice of the Structural Welding Code Sections 1 through 6, AWS D1.1/D1.1M and in accordance with the practice specified by the producer of the metal being welded.

]2.5.2 Stops and Beads

Provide form and loose stops and beads from 20 gage steel. Provide for glazed and other openings in standard steel frames. Secure beads to frames with oval-head, countersunk Phillips self-tapping sheet metal screws or concealed clips and fasteners. Space fasteners approximately 12 to 16 inches on center. Miter molded shapes at corners. Butt or miter square or rectangular beads at corners.

2.5.3 Anchors

Provide anchors to secure the frame to adjoining construction. Provide steel anchors, zinc-coated not lighter than 18 gage.

2.5.3.1 Wall Anchors

Provide at least three anchors for each jamb. For frames which are more than 7.5 feet in height, provide one additional anchor for each jamb for each additional 2.5 feet or fraction thereof.

- a. Masonry: Provide anchors of corrugated or perforated steel straps or 3/16 inch diameter steel wire, adjustable or T-shaped;
- b. Stud partitions: Weld or otherwise securely fasten anchors to backs of frames. Design anchors to be fastened to closed steel

studs with sheet metal screws, and to open steel studs by wiring or welding;

- c. Completed openings: Secure frames to previously placed concrete or masonry with expansion bolts in accordance with SDI/DOOR 111; and

2.5.3.2 Floor Anchors

Provide floor anchors drilled for 3/8 inch anchor bolts at bottom of each jamb member.

2.6 FIRE AND SMOKE DOORS AND FRAMES

The requirements of NFPA 80 and NFPA 105 takes precedence over details indicated or specified.

2.6.1 Labels

Provide fire doors and frames bearing the label of Underwriters Laboratories (UL), Factory Mutual Engineering and Research (FM), or Warnock Hersey International (WHI) attesting to the rating required. Testing must be in accordance with NFPA 252 or UL 10C. Provide labels that are metal with raised letters, bearing the name or file number of the door and frame manufacturer. Labels must be permanently affixed at the factory to frames and to the hinge edge of the door. Do not paint door and labels.

2.7 DOOR SEALS

2.8 HARDWARE PREPARATION

Provide minimum hardware reinforcing gauges as specified in SDI/DOOR A250.6 except provide 7 gauge at hinges and 14 gauge at strike minimum. Drill and tap doors and frames to receive finish hardware. Prepare doors and frames for hardware in accordance with the applicable requirements of SDI/DOOR A250.8 and SDI/DOOR A250.6. For additional requirements refer to ANSI/BHMA A156.115. Drill and tap for surface-applied hardware at the project site. Build additional reinforcing for surface-applied hardware into the door at the factory. Punch door frames, with the exception of frames that will have weatherstripping to receive a minimum of two rubber or vinyl door silencers on lock side of single doors and one silencer for each leaf at heads of double doors. Set lock strikes out to provide clearance for silencers.

2.9 FINISHES

2.9.1 Factory-Primed Finish

Thoroughly clean all surfaces of all interior doors and frames then chemically treat and factory prime with a rust inhibiting coating as specified in SDI/DOOR A250.8, or paintable A25 galvanized steel without primer. Where coating is removed by welding, apply touchup of factory primer.

2.10 FABRICATION AND WORKMANSHIP

Provide finished doors and frames that are strong and rigid, neat in appearance, and free from defects, waves, scratches, cuts, dents, ridges, holes, warp, and buckle. Provide molded members that are clean cut, straight, and true, with joints coped or mitered, well formed, and in true alignment. Dress exposed welded and soldered joints smooth. Design door frame sections for use with the wall construction indicated. Corner joints must be well formed and in true alignment. Conceal fastenings where practicable. Frames must be welded construction. On wraparound frames for masonry partitions, provide a throat opening 1/8 inch larger than the actual masonry thickness. Design other frames in exposed masonry walls or partitions to allow sufficient space between the inside back of trim and masonry to receive caulking compound.

2.11 PROVISIONS FOR GLAZING

Materials are specified in Section 08 81 00, GLAZING.

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Frames

Set frames in accordance with SDI/DOOR A250.11. Plumb, align, and brace securely until permanent anchors are set. Anchor bottoms of frames with expansion bolts or powder-actuated fasteners. Build in or secure wall anchors to adjoining construction. Backfill frames with mortar. Coat inside of frames with corrosion-inhibiting bituminous material. For frames in exterior walls, ensure that stops are filled with rigid insulation before grout is placed.

3.1.2 Doors

Hang doors in accordance with clearances specified in SDI/DOOR A250.8. After erection and glazing, clean and adjust hardware.

3.1.3 Fire Doors and Frames

Install fire doors and frames, including hardware, in accordance with NFPA 80.

3.2 PROTECTION

Protect doors and frames from damage. Repair damaged doors and frames prior to completion and acceptance of the project or replace with new, as directed. Wire brush rusted frames until rust is removed. Clean thoroughly. Apply an all-over coat of rust-inhibitive paint of the same type used for shop coat.

3.3 CLEANING

Upon completion, clean exposed surfaces of doors and frames thoroughly. Remove mastic smears and other unsightly marks.

-- End of Section --